



**PUBLIC HEALTH DIVISION  
Drinking Water Services**

Kate Brown, Governor



**800 NE Oregon Street, #640**

**Portland, OR 97232-2162**

**Phone 971-673-0405**

**FAX 971-673-0694**

**TTY-Nonvoice 971-673-0375**

6/8/2020

JEREMY TOWER  
WELCHES WATER COMPANY  
PO BOX 1981  
SANDY, OR 97055

RE: Administrative Notice for failure to submit disinfection byproducts (DBP) sample results.- Please note corrected due date

Dear JEREMY TOWER,

This letter is to inform you that DBP sampling results have not been reported for PWS # OR4100937 during the previous monitoring period.

2 DBP (both HAA5 & TTHM) sample(s) collected every year in June

2DBP-01                      EXPECTED HIGH HAA5

2DBP-02                      EXPECTED HIGH THM

This is a violation of Oregon Administrative Rule (OAR) 333-061-0036(4)(a)(B) or OAR 333-061-0040.

DBP samples must be collected during the month and at the location with the highest DBP concentrations. Be sure to collect your water samples at the location listed online and during the month listed above.

Also, sampling results must be received by DWS no later than January 10, 2021. If the required sampling results are not received, it may result in enforcement action, which could include the assessment of civil penalties.

You can submit sampling results to DWS using one of the following methods:

- Fax the report to (971) 673-0694

*For faxed data, please include a cover sheet with the number of pages including the cover, your name, and your phone number.*

- Email the report to: [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)
- Mail the report to: Water Quality Reports  
P.O. Box 14350  
Portland, OR 97293-0350

Please contact Joel Ferguson/Julie Hamilton with CLACKAMAS COUNTY at (503) 742-5367 if you have any questions.

Your immediate attention to this matter is appreciated.

Respectfully,

Drinking Water Services