

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

November 28, 2017

Marvin Akins
City of Yoncalla
2640 Eagle Valley Rd
Yoncalla, OR 97499

RE: Notice of failure to correct significant deficiencies at the City of Yoncalla public water system, ID# OR4100958


This letter is to inform you the Oregon Health Authority was not notified that significant deficiencies were corrected by the April 3, 2017 due date at the City of Yoncalla public water system. Two of the deficiencies, the roof and access hatch are not watertight and the lack of a screened vent at the water system's reservoir, are both considered a direct pathway for contamination to enter a water system and are priorities for correction.

The failure to correct the deficiencies by the original due date following the December 7, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0421. Your immediate attention to this matter is appreciated.

Respectfully,



Janet Brock
Oregon Health Authority, Drinking Water Services

cc: Rebecca Templin, Drinking Water Services