

February 16, 2017

Cheri and Ken Hick
Cline Falls Mobile Home Park
Cascade Investment and Management Group, LLC
PO Box 16756
Portland, OR 97292

RE: Notice of failure to correct significant deficiencies at the Cline Falls Mobile Home Park public water system

Records indicate you own the Cline Falls Mobile Home Park (Cline Falls) public water system located at 7915 W Highway 126 in Redmond, Oregon. The Cline Falls water system is a community public water system identified by ID# OR4101126 that serves approximately 85 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rules 333-061-0005 to 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) has reviewed the operation of the Cline Falls water system. This review has found that you are not in compliance with OAR 333-061-0076(6)(b) and therefore not meeting your responsibilities as a water supplier.

OAR 333-061-0076(6)(b) requires water suppliers to correct significant deficiencies within 120 days of notification or to be in compliance with an approved corrective action schedule. You have not reported that significant deficiencies were corrected by the October 6, 2016 due date at the Cline Falls water system. One deficiency, the lack of a watertight casing and sanitary seal for a source water well, is considered a direct pathway for contamination to enter a water system and is a priority for correction. The failure to correct this deficiency by the due date following the June 1, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6).

You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Cline Falls water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0407 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Michelle Byrd, Oregon Health Authority, Drinking Water Services
Eric Chamberlain, Cline Falls Mobile Home Park
Jeff Freund, Deschutes County Environmental Health