

April 25, 2018

Cheri Cooley
Cline Falls Mobile Home Park
PO Box 33124
Portland, OR 97292

RE: Warning letter for failure to install disinfection treatment at the Cline Falls Mobile Home Park public water system

Agency records indicate that you own the Cline Falls Mobile Home Park water system located at 7915 W Highway 126 in Redmond, Oregon. You are therefore a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020 and have specific responsibilities as defined in OAR 333-061-0025.

The Cline Falls Mobile Home Park (Cline Falls) water system is a community public water system identified by public water system ID OR41-01126, serves approximately 85 people, and is subject to regulation according to ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Cline Falls water system. This review has found that you are not in compliance with the following Oregon Administrative Rule and therefore not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

- OAR 333-061-0032(6)(g) requires, in part, water suppliers to install treatment for disinfectant residual maintenance when three or more coliform investigations as described in OAR 333-061-0078 are triggered within a twelve month period. This treatment must be installed within six months unless an alternate schedule is approved. The presence of coliform bacteria in drinking water at the Cline Falls water system triggered a third coliform investigation on April 7, 2017 and as of October 7,

2017 the required water treatment was not installed as required by the rule nor was an alternate schedule approved. This constitutes a violation of OAR 333-061-0032(6)(g).

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violation identified above, you are required to complete the following actions.

1. You must submit construction plans for treatment to maintain a disinfectant residual throughout the Cline Falls water system.
 - The plans must be submitted to DWS within 30 days of the date of this letter.
 - Construction plans must be approved by DWS prior to any construction or installation taking place and construction must be completed according to the plans approved by DWS.
2. You must ensure construction and installation of the treatment specified above is completed within 90 days of the date of this letter.
 - Construction of all improvements or modifications at the Cline Falls water system must meet the applicable construction standards specified in OAR 333-061-0050.

If you do not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action and may include the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact me at 971-673-0405 to discuss the actions required in this letter.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels

Compliance Specialist

Oregon Health Authority, Drinking Water Services

cc: Michelle Byrd, Oregon Health Authority, Drinking Water Services
Jeff Freund, Deschutes County Environmental Health
Ken Hick, Cline Falls Mobile Home Park
Gene Ramey, Cline Falls Mobile Home Park