

**Health and Human Services  
Environmental Public Health**

**Mike Obereigner, REHS**  
*Environmental Health Specialist*  
1000 E. Main St.  
Medford, OR 97504  
Phone: (541) 774-7843  
Fax: (541) 779-7987  
obereimo@jacksoncounty.org

July 6, 2015

John Staver  
3030 Upper Applegate Rd  
Jacksonville, OR 97530

Dear Mr. Staver,

This letter is a follow-up to the arsenic sample collected at PWS 01165 McKee Bridge Mobile Home Park on June 29, 2015. The 0.03 ppm sample result exceeds the 0.01 ppm Maximum Contaminant Level (MCL), and, as a result, the Oregon Health Authority is requiring the following action from McKee Bridge Mobile Home Park:

- (1) Troubleshoot/diagnose/repair the arsenic treatment system within two weeks.
- (2) Collect an arsenic sample after repairs are completed and send the result to our office when you receive it.
- (3) Collect arsenic samples on a monthly schedule for a period of no less than three months beginning in August.
- (4) Submit a corrective action plan to our office within two weeks. Include a timeline for each specific follow-up action you will be taking.

Please feel free to contact me if you have any questions.

Sincerely,

Mike Obereigner, REHS  
Environmental Health Specialist

C.c. Scott Curry, OHA-DWS  
Casey Lyon, OHA-DWS  
Brad Daniels, OHA-DWS  
Steve Krupicka