

January 11, 2019

Fred C. Bell
Sundowner Mobile Home Park
10805 South E Street
Island City, OR 97650

RE: Notice of failure to correct significant deficiencies at the Sundowner Mobile Home Park public water system

Records indicate that Sundowner Mobile Home Park (Sundowner MHP) owns a public water system serving the mobile home park located at 1806 26th St, La Grande, OR 97850. The Sundowner MHP water system is a community public water system identified by ID# OR4101344 that serves approximately 160 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. The Sundowner MHP is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Sundowner MHP water system. This review has found that you are not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier. OAR 333-061-0076(6) requires water suppliers to correct significant deficiencies or comply with an approved corrective action schedule.

You have not reported that the significant deficiencies from the Dec. 27, 2017 survey at the Sundowner MHP were corrected by the May 14, 2018 deadline. One deficiency, the screen missing on existing well vent, is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$100.00 for every distinct rule violation and for every day the Sundowner MHP water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,

A handwritten signature in blue ink that reads "Abbie Spielman". The signature is written in a cursive, flowing style.

Abbie Spielman
Oregon Health Authority, Drinking Water Services

cc: Ryan Zastrow, Union County Environmental Health
Bill Goss/Amy Word, Drinking Water Services