

May 7, 2019

TIA ONTKO
HAPPY HOLLOW WATER COMPANY
13050 NE LAWSON ROAD
PRINEVILLE, OR 97754

RE: Notice of failure to correct significant deficiencies at the HAPPY HOLLOW WATER COMPANY public water system

Records indicate you own and operate the Happy Hollow Water Company (H. Hollow) a public water system which serves homes located along NW Peacock Walk Prineville, OR 97754. The H. Hollow water system is a community public water system identified by ID# OR4101353 that serves approximately 42 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the H. Hollow water system. This review has found that you are not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier.

OAR 333-061-0076(6) requires water suppliers to correct significant deficiencies or to be in compliance with an approved corrective action schedule following a sanitary survey. You have not reported that the significant deficiencies were corrected by the April 8, 2019 deadline. One deficiency, *Roof and access hatch not watertight* is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

Happy Hollow Water Company

Page 2

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50.00 for every distinct rule violation and for every day the H. Hollow water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,



Abbie Spielman

Oregon Health Authority, Drinking Water Services

cc: Jean Edwards, Happy Hollow Water Company
Max Hamblin, Crook County Environmental Health
Michelle Byrd, Drinking Water Services