

February 28, 2017

Butch Rogers
Deer Trail Water System
22648 Nelson Rd.
Bend, OR 97701

RE: Notice of failure to correct significant deficiencies at the Deer Trail public water system

Records indicate you operate the public water system serving homes along Deer Tail Road in Bend, Oregon south of Alfalfa Market Road. The Deer Trail water system is a community public water system identified by ID# OR4101367 that serves approximately 45 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rules 333-061-0005 to 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) has reviewed the operation of the Deer Trail water system. This review has found that you are not in compliance with OAR 333-061-0076(6)(b) and therefore not meeting your responsibilities as a water supplier.

OAR 333-061-0076(6)(b) requires water suppliers to correct significant deficiencies within 120 days of notification or to be in compliance with an approved corrective action schedule. You have not reported that significant deficiencies were corrected by the November 23, 2016 due date at the Deer Trail water system. One deficiency, the lack of a watertight access hatch or roof for a water storage facility, is considered a direct pathway for contamination to enter a water system and is a priority for correction. The failure to correct this deficiency by the due date following the July 19, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6).

Deer Trail Water System

Page 2

You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Deer Trail water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0407 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Michelle Byrd, Oregon Health Authority, Drinking Water Services
Pat Aldrich, Deer Trail Water System
Jeff Freund, Deschutes County Environmental Health