



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

April 19, 2023

Patrick Aldrich
Deertrail Water Company
62335 Deer Trail Road
Bend, OR 97701

RE: Notice of failure to correct significant deficiencies at the Deertrail Water Company public water system

Records indicate Deertrail Water Company owns and operates the public water system (hereinafter "Water System"), identified by public water system ID# OR4101367 and serving residences along and near Deer Trail Road, east of Bend, Oregon. Deertrail Water Company (hereinafter "Water Supplier") is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Water System is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.

OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies identified during sanitary surveys or to comply with an approved corrective action schedule. The Oregon Health Authority, Drinking Water Services (DWS) reviewed the operation of the Water System and found that two significant deficiencies remain uncorrected following two consecutive sanitary surveys:


1. Failure to submit a cross connection annual summary report; and
2. Failure to employ or utilize a certified water system operator.

Water Supplier has not reported that these deficiencies were corrected by the specified due dates, following the surveys conducted on October 10, 2019 and September 1, 2022 respectively. Water Supplier is therefore not in compliance with OAR 333-061-0076(5) and not meeting its responsibilities as a water supplier.

Please submit written verification to bradley.k.daniels@oha.oregon.gov within 30 days of the date of this notice, demonstrating that this deficiency was corrected.

If Water Supplier does not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Contact me at bradley.k.daniels@oha.oregon.gov or (503) 735-5438 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Michelle Byrd, Oregon Health Authority, Drinking Water Services
Jeff Freund, Deschutes County Environmental Health