

November 28, 2017

Shirley Bower  
Rink Creek Water District  
PO Box 65  
Coquille, OR 97423

RE: Notice of failure to collect lead and copper samples in the seasonal period at the Rink Creek Water District public water system, ID# OR4101402


This letter is to inform you that the lead and copper samples collected October 12, 2017 and received by the Oregon Health Authority on October 17, 2017 were collected outside the required seasonal period between June 1<sup>st</sup> and September 30<sup>th</sup>.

For community water systems assigned three-year lead and copper monitoring schedules, the failure to collect lead and copper samples between June 1<sup>st</sup> and September 30<sup>th</sup> is a violation of Oregon Administrative Rule (OAR) 333-061-0036(2)(c).

To return the Rink Creek Water District to compliance, collect lead and copper samples between June 1, 2018 and September 30, 2018, and report the sample results to DWS no later than October 10, 2018.

If you have any questions about this notice, contact me at 971-673-0421. Your immediate attention to this matter is appreciated.

Respectfully,



Janet Brock  
Oregon Health Authority, Drinking Water Services

cc: Betsy Parry, Oregon Health Authority, Drinking Water Services  
Rick Hallmark, Coos County Health Department  
Nathan Stevens, DRC, Rink Creek Water District