



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Kate Brown, Governor

**Oregon
Health
Authority**

800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

6/16/2022

PAM STAUBER

SANTIAM MEADOWS COMMUNITY WS

6067 78TH AVE SE

SALEM, OR 97317

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4105392

Dear PAM STAUBER,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 12/16/2022. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Greg DeBlase/Alisa Zastoupil/Andrew Duncan at (503) 588-5407.

Respectfully,

Drinking Water Services

cc: Chantal Wikstrom, DWS

Greg DeBlase/Alisa Zastoupil/Andrew Duncan, Marion County