



800 NE Oregon Street, Suite #640  
Portland, OR 97232-2162  
(971) 673-0405  
(971) 673-0694 – FAX  
<http://healthoregon.org/dwp>

January 14, 2020

Gary Helvig  
Anderson Mountain Springs  
98486 Carla Lane  
Myrtle Point, OR 97458

**Re: Anderson Mountain Springs Site Visit**

Dear Mr. Helvig:

The Oregon Health Authority (OHA), Drinking Water Services (DWS) conducted a public water system site visit at Anderson Mountain Springs on May 8, 2019. The purpose of this visit was to evaluate the water system source, treatment, storage, distribution network, operation, maintenance, and management in terms of capacity to provide safe drinking water.

Please complete these follow-up actions by **April 30, 2020**:

**1. An intercepting ditch shall be provided above the spring to effectively divert surface water - OAR 333-061-0050(2)(b)(i)**

As depicted (right), there does not appear to be an adequate intercepting ditch around the spring collection site. The upland portion of the spring culvert cover had detritus overflowing onto it.

**2. Products added to public water systems for treatment, purposes including but not limited to disinfection shall meet the requirements of NSF Standard 60: Drinking Water Treatment Chemicals - Health Effects or equivalent. - OAR 333-061-0087(6)**

Documentation of calcium hypochlorite NSF (or equivalent) certification was not reviewed at the time of inspection - Please submit documentation.



If you have any questions or concerns, please contact me at (971) 673-5393 or by email at [daniel.l.hough@state.or.us](mailto:daniel.l.hough@state.or.us). Your cooperation is appreciated.

Sincerely,

Daniel Hough, REHS  
Small Drinking Water System Specialist

CC: Rick Hallmark, Coos County Health Department