



800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

July 25, 2024

Cody or Nicole Nelson
River Village MHP
5445 32nd Ave SW
Seattle, WA 98126

RE: Violation of the maximum contaminant level for *E. coli* bacteria at the River Village MHP public water system, ID# 05854

Dear Cody and Nicole Nelson,

Recent samples reported for your water system indicate coliform bacteria in the drinking water caused a violation of the maximum contaminant level (MCL) for *E. coli* bacteria. The presence of these bacteria indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. OAR 333-061-0097

Please continue consultation with Bill Goss or Amy Word at 541-276-8006 so that you can disinfect the water system and abate the contamination as quickly as possible.

- 1) You must cooperate with Bill Goss or Amy Word during an inspection of the water system and investigation to determine the source of the bacteria in the drinking water system, and to identify the most effective corrective action. You will be contacted in the near future, if you have not already been contacted, to schedule the inspection and investigation. When it is complete, you must correct any sanitary defects identified during the investigation process and collect water samples to demonstrate bacteria are no longer present in the drinking water.

You can contact DWS circuit rider for technical assistance at mgochnour@civilwest.net or 541-266-8601. Visit the webpage: <https://www.oregon.gov/oha/PH/HEALTHYENVIRONMENTS/DRINKINGWATER/OPERATIONS/Pages/circuitrider.aspx> for more information about the DWS circuit rider program.

The actions described in this letter are required by Oregon Administrative Rules 333-061-0025, 333-061-0030 and 333-061-0042. Please contact me at bradley.k.daniels@oha.oregon.gov or (503) 735-5438 if you have any questions or to discuss the actions required in this letter.

Thank you for your immediate attention to this matter.

Respectfully,



Brad K. Daniels
Compliance Specialist
Oregon Health Authority, Drinking Water Services

cc: Bill Goss, Oregon Health Authority, Drinking Water Services
Amy Word, Oregon Health Authority, Drinking Water Services