

January 29, 2019

Charles Wallace  
Crane Prairie Resort  
PO Box 1171  
Bend OR 97709

RE: Notice of failure to correct significant deficiencies at the Crane Prairie Resort public water system

Records indicate that you own the Crane Prairie Resort public water system serving the RV park, vacation cabins, and general store collectively known as the Crane Prairie Resort located near the intersection of Forrest Service Roads 4270 and 4255-255, Bend OR 97709. The Crane Prairie Resort water system is a transient non-community public water system identified by ID# OR4190133 that serves approximately 100 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Crane Prairie Resort water system. This review has found that you are not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier. OAR 333-061-0076(6) requires water suppliers to correct significant deficiencies or comply with an approved corrective action schedule.

You have not reported that the significant deficiencies from the August 27, 2018 survey at Crane Prairie Resort were corrected by the Dec. 31, 2018 deadline. One deficiency, sanitary seal and casing not watertight, is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this

deficiency is corrected by March 15, 2019 or prior to the resort opening in April or May 2019.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50.00 for every distinct rule violation and for every day the Crane Prairie Resort water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,

A handwritten signature in blue ink that reads "Abbie Spielman". The signature is written in a cursive style and is positioned above the printed name.

Abbie Spielman  
Oregon Health Authority, Drinking Water Services

cc: Jeff Freund, Deschutes County Environmental Health  
Michelle Byrd, Drinking Water Services