



# Marion County

OREGON

## HEALTH DEPARTMENT

### BOARD OF COMMISSIONERS

Sam Brentano  
Kevin Cameron  
Janet Carlson

### ADMINISTRATOR Roderick P. Calkins, PhD

ADMINISTRATION  
(503) 588-5357  
FAX (503) 364-6552

ENVIRONMENTAL  
HEALTH  
(503) 588-5346  
FAX (503) 566-2986

Richard Sherman, R.S.  
Supervisor  
(503) 588-5387

Health.co.marion.or.us

June 24, 2015

Jason Geiling  
Last Chance Saloon, PWS 4190299  
1547 Joseph St S  
Salem, OR 97302

RE: Compliance Schedule for Violations at the Last Chance Saloon public water system

Dear Mr. Geiling,

This letter is a follow-up to our conversation regarding the timeframe for correction of the violations specified below at the Last Chance Saloon. As we discussed, when a public water system has unresolved violations for more than 5 months, these violations must then be resolved within 90 days or the water system will be referred for formal enforcement.

The Last Chance Saloon water system has the following violations that must be resolved within 90 days:

**Violation #1:** [OAR 333-061-0030] Total Coliform MCL (July- Sept 2014)

**Violation #2:** [OAR 333-061-0025] Routine Coliform – Did not report any (Oct 2014)

**Violation #3:** [OAR 333-061-0030] Total Coliform MCL (Mar-May 2015)

**Violation#4:** [OAR 333-061-0025] Routine Coliform – Did not report any (April 2015)

Per our conversations, you have agreed to resolve the above violations according to the following compliance schedule:

1) The water system agrees to have the well/distribution evaluated by a water professional and make any repairs found that may be contributing to



the unresolved total coliform detection. This may include properly shock chlorinating and flushing the well/distribution. This must be done by July 31, 2015.

- 2) The water system must provide a copy of the Public Notice issued for the March 2015 Total Coliform MCL violation. The notice must be emailed to me at [gdeblase@co.marion.or.us](mailto:gdeblase@co.marion.or.us) by July 31, 2015.
- 3) The water system must monitor for total coliform (routine 2<sup>nd</sup> quarter sample) by June 30, 2015 and report the results to the state by July 10, 2015.
- 4) The water system must monitor for total coliform (routine 3<sup>rd</sup> quarter sample) by September 30, 2015 and report the results to the state by October 10, 2015. I recommend taking the 3<sup>rd</sup> quarter routine sample in July. Once two consecutive quarterly routine total coliform samples are reported to be in compliance, the violations will be returned to compliance.

Failure to comply with the above compliance schedule may result in formal enforcement action which could include the assessment of civil penalties. If you have any questions or concerns, please call me at (503) 588-5407.

Thank you for your cooperation.

Sincerely,



Greg DeBlase, REHS  
Environmental Health Specialist  
Marion County Environmental Health

cc: Drinking Water Services Enforcement  
Oregon Health Authority, Drinking Water Services