

2/26/2025

DANIEL GRABER
WESTERN CHRISTIAN SCHOOL
9045 WALLACE RD NW
SALEM, OR 97304

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4190582

Dear DANIEL GRABER,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 8/30/2025. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Christina Tisdell/Justine Bova at (503) 623-9237.

Respectfully,

Drinking Water Services

cc: Evan Hofeld, DWS

Christina Tisdell/Justine Bova, Polk County