



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

May 4, 2023

Debbie Thomason
Thomason Enterprises, Inc.
PO Box 99
Merlin, OR 97532

RE: Notice of failure to correct significant deficiencies at the Galice Resort public water system

Records indicate Thomason Enterprises, Inc. owns and operates the public water system serving Galice Resort (hereinafter “Water System”), identified by public water system ID# OR4190808 and located at 11744 Galice Road in Merlin, Oregon . Thomason Enterprises, Inc. (hereinafter “Water Supplier”) is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(151) and has specific responsibilities as defined in OAR 333-061-0025.

The Water System is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.


OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies or to comply with an approved corrective action schedule. The Oregon Health Authority, Drinking Water Services (DWS) has reviewed the operation of the Water System and found that five significant deficiencies were identified during a sanitary survey conducted on October 21, 2021. Water Supplier has not reported that these deficiencies were corrected by the revised March 31, 2022 due date. Water Supplier is therefore not in compliance with OAR 333-061-0076(5) and not meeting its responsibilities as a water supplier.

One of the deficiencies, the lack of a flap valve, screen or equivalent protection for the overflow from finished water storage, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

Please submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If Water Supplier does not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$250 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at bradley.k.daniels@oha.oregon.gov or (503) 735-5438 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Kent Downs, Oregon Health Authority, Drinking Water Services