

May 2, 2016

Solomon Weil
Camp Myrtlewood
49658 Myrtle Creek Rd.
Myrtle Point, OR 97458

RE: Notice of failure to correct significant deficiencies at Camp Myrtlewood, public water system ID# OR4190861

Dear Mr. Weil,

This letter is to inform you the Oregon Health Authority has not been notified that significant deficiencies were corrected by the September 24, 2015 due date at the Camp Myrtlewood water system. Two of the deficiencies are considered a direct pathway for contamination to enter a water system and are a priority for correction. They are:


- The lack of a screened vent for a finished water storage facility; and
- Monitoring turbidity at the incorrect location.

The failure to correct the deficiencies by the original due date, following the July 21, 2015 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if, in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies from the July 21, 2015 sanitary survey have already been corrected. Otherwise, you must correct the deficiencies identified in this notice within 30 days and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact to Betsy Parry at 541-726-2587x30. Your immediate attention to this matter is appreciated.

Respectfully,



Brad K. Daniels
Oregon Health Authority, Drinking Water Services

cc: Betsy Parry, Oregon Health Authority, Drinking Water Services