



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Tina Kotek, Governor

**Oregon
Health
Authority**

800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

11/6/2023

JASON JOURNEY
SUMMER LAKE WILDLIFE MNGMT
53447 HWY 31
SUMMER LAKE, OR 97640

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4191135

Dear JASON JOURNEY,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 5/2/2024. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Russ Kazmierczak at (971) 599-0121.

Respectfully,

Drinking Water Services

cc: Russ Kazmierczak, DWS