

Raymond M. Rask
Pliska Investments, LLC
Space Age Fuels
1200 SW Main St.
Portland, OR 97205-2040

RE: Extension to the Notice of Non-Compliance issued on April 10, 2013 regarding the Space Age Fuels public water system, PWS OR4191240

Pliska Investments, LLC (the Company) and Space Age Fuels, Inc own and operate the Space Age Fuels water system in Hermiston, Oregon. The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) issued a Notice of Non-Compliance (Notice) to the Company regarding its operation of the Space Age Fuels water system on April 10, 2013.

DWS received a request on behalf of the Company for an extension to the deadlines specified in the Notice. The extension request states an extension is necessary because part of the project could not be completed by the deadline.

Based on the Company's progress and development of a new well free from nitrate contamination, DWS is granting the Company an extension until October 31, 2013 to complete rehabilitation of a nitrate treatment system.

The extension is granted with the following conditions:

1. The Company must report sample results to DWS that demonstrate drinking water produced by the Space Age Fuels water system does not contain levels of nitrate exceeding the maximum contaminant level as prescribed by OAR 333-061-0030(1).
 - Samples must be collected at times representative of water produced directly by the new well and water produced by the shallow well when the nitrate treatment system is in use.
 - Sample results must be reported to DWS no later than October 31, 2013.

2. The Company must post public notice such that it is received by individuals served drinking water from the Space Age Fuels water system. The public notice must continue to be posted until sample results demonstrate that nitrate does not exceed the maximum contaminant level as specified above.
3. The Company must ensure that Well #1, identified by well log number UMAT 5620, serving the Space Age Fuels water system is disconnected from the water system and formally abandoned according to standards set forth by the Oregon Water Resources Department in Oregon Administrative Rules Chapter 690, Division 220.
Abandonment of the well must be completed no later than October 31, 2013.

This extension only does not constitute a waiver, modification, or suspension of any other compliance actions, requirements, or information contained in the Notice issued on April 10, 2013, which remain in full force and effect.

Dated this third day of September, 2013.



Brad K. Daniels, Enforcement Coordinator
Center for Health Protection

cc: Dennis Boeger, Boeger and Associates
Bill Goss, DWS
James Pliska, Pliska Investments, LLC