



BEFORE THE STATE OF OREGON  
OREGON HEALTH AUTHORITY  
CENTER FOR HEALTH PROTECTION

In the Matter of

Corvallis School District 509J - Dixie  
Elementary Public Water System

BILATERAL COMPLIANCE AGREEMENT

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) and Corvallis School District 509J agree to the following:

1. Corvallis School District 509J is a water supplier (hereinafter “Water Supplier”) as defined in Oregon Revised Statute (ORS) 448.115 and Oregon Administrative Rule (OAR) 333-061-0020. The responsibilities of water suppliers are identified in OAR 333-061-0025.
2. Water Supplier owns and operates the public water system (hereinafter “Water System”), identified by public water system ID# OR4191671 and serving Dixie Elementary School at 33461 SE Peoria Road in Corvallis, Oregon. The Water System is a non-transient non-community water system serving approximately 100 people and subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.
3. DWS reviewed the operation of the Water System pursuant to its authority in ORS 431A.010, 448.150 and 448.255. DWS has determined that water supplier did not maintain water quality parameters at or above the minimum values for optimal corrosion control treatment. Water treated with optimal corrosion control but where

minimum water quality parameter values are not met represents a potential public health hazard.

4. This Bilateral Compliance Agreement (“Agreement”) is entered into between DWS and Water Supplier to address the failure to properly operate optimal corrosion control treatment at the Water System. This Agreement establishes the corrective action(s) that Water Supplier must take and the deadlines for completing those actions with the purpose of returning the water system to compliance with the applicable requirements. The corrective actions and respective deadlines are described in detail below.

#### FINDINGS OF FACT AND CONCLUSIONS OF LAW

1. Water Supplier is required to meet all the responsibilities for water suppliers described in OAR 333-061-0025.
2. OAR 333-061-0034(3)(1) requires, in part, water suppliers to operate and maintain optimal corrosion control treatment such that water quality parameters are maintained at or above the minimum values designated by DWS. Water Suppliers are out of compliance with this rule if water quality parameters are below the minimum values designated by DWS on more than nine days during any six-month compliance period.
3. Optimal corrosion control treatment was installed at the Water System and approved by DWS in November 2013. Prior to the installation of this treatment, lead exceeded the action level identified in OAR 333-061-0030(1).
4. Measurements reported for the Water System demonstrated that water quality parameters were below the designated minimums for 18 days cumulatively between January 1 and June 30, 2023, and for 38 days cumulatively between July 1 and December 31, 2023. Water Supplier is therefore not in compliance with OAR 333-061-0034(3)(1).
5. Neither lead nor copper exceeded the action level specified in OAR 333-061-0030(1) during the periods specified in Findings of Fact No. 4.
6. Water Supplier installed treatment to maintain water quality parameters at or above the minimum values designated by DWS and has complied with OAR 333-061-0034(3)(1) every month since October 2023.

### CORRECTIVE ACTIONS

Water Supplier agrees to take the following corrective actions and meet the deadlines set out below:

1. Water Supplier shall continue to measure water quality parameters every month according to OAR 333-061-0036(10)(f) and report the results to DWS according to OAR 333-061-0040(1)(h).
  - Water Supplier shall have satisfied the Agreement when measurements demonstrate water quality parameters were maintained at or above the minimum values designated by DWS, in compliance with OAR 333-061-0034(3)(1), for a six-month monitoring period.

### DWS RESPONSIBILITIES


- DWS shall review and approve any corrective action plan or construction plans submitted by Water Supplier within thirty (30) days of receipt. DWS shall approve or require changes to the submitted plans immediately upon completing the review.

### GENERAL PROVISIONS


1. Water Supplier satisfies the terms of this Agreement by completing the corrective actions listed above according to the deadlines specified herein.
2. This Agreement does not constitute a waiver, suspension or modification of the requirements of the Oregon Drinking Water Quality Act; ORS 448.115 to 448.285 and administrative rules OAR 333-061-0005 to 333-061-0272, which remain in full force and effect.
3. This Agreement does not relieve Water Supplier of any responsibilities or liabilities established by any applicable federal, state, or local law or regulation.
4. If Water Supplier fails to complete any of the corrective actions listed above or fails to meet any of the listed deadlines, DWS may pursue any enforcement action, which may include assessment of civil penalties or other legal remedies pursuant to ORS 431A.010, 431.155, 448.255 and 448.280. If DWS proceeds with such an enforcement action, Water Supplier will have the right to a hearing.

5. DWS may consider the findings of fact and violations cited in the conclusions of law of this Agreement for purposes of any future enforcement action or sanction involving Water Supplier.
6. Water Supplier is aware of its rights to contest the violations listed in this Agreement in a contested case hearing under the Administrative Procedure Act (Oregon Revised Statutes, Chapter 183) and its rights to judicial review of a final order issued in the contested case. Water Supplier freely and voluntarily waives all rights to a contested case hearing and to all judicial review of the findings of fact or conclusions of law contained in this Agreement in a proceeding brought by DWS to enforce this Agreement.
7. This Agreement may be executed in one or more multiple counterparts, including facsimile, scanned, and electronically transmitted counterparts, each of which shall constitute an original and all of which together shall constitute one and the same agreement.

Date March 1<sup>st</sup> 2024

  
\_\_\_\_\_  
Doug Tiller  
Facilities Manager  
Corvallis School District 509J

Date 3/5/2024

A handwritten signature in black ink, appearing to read "Samina".

---

Samina Panwhar, Manager  
Drinking Water Services  
Oregon Health Authority

cc: Amy Bleekman, Oregon Health Authority, Drinking Water Services  
Stephen Kirkley, Linn County Environmental Health  
Mike Ruark, Corvallis School District 509J