

3/13/2025

JERI BASKIN
THE DAM BAR
38854 HWY 228
SWEET HOME, OR 97386

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4191675

Dear JERI BASKIN,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 9/15/2025. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Alyson Reynolds/Rebecca Duerr/Nate Tisdell/Shane Sanderson/Stephen Kirkley at (541) 967-3821.

Respectfully,

Drinking Water Services

cc: Nick Alviani, DWS

Alyson Reynolds/Rebecca Duerr/Nate Tisdell/Shane Sanderson/Stephen Kirkley,
Linn County