

February 19, 2019

Dean and Donna Logan
2956 Rogue River Hwy.
Grants Pass, OR 97527

RE: Warning letter for failing to conduct microscopic particulate analysis at the Riverpark RV Resort public water system

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has determined, according to OAR 333-061-0032(7), that the well, identified as Well #1, supplying the Riverpark RV Resort water system (hereinafter "Water System") must be evaluated for the influence of surface water because of its proximity to the Rogue River and initial microscopic particulate analysis (MPA) screening results at a risk score of 10.

The initial results require one additional MPA sample to be collected according to the criteria provided below:

The additional MPA sample must be collected during or shortly after a period of significant rainfall or snow melt resulting in high flow and water level in the Rogue River. Data obtained from the Rogue River indicates it is at high flow when the discharge is greater than 10,000 cubic feet per second (cfs). This MPA sample must be collected no later than April 30, 2019 unless the specified conditions in the Rogue River do not occur before this date.

To further assist you with sampling at the proper time based upon flow levels in the river; you may opt to utilize an automated service known as **WaterAlert** from U.S. Geological Survey. The service can send an e-mail or text (SMS) message to the user when they sign up for the service. Parameters such as discharge and gauge height levels of the Rogue River at Grants Pass Oregon can be selected. The service can be accessed here:

http://water.usgs.gov/wateralert/subscribe2/?site_no=14361500&parm=00060

Please contact Shawn Stevenson at 541-726-2587, extension 32 if you have any questions about this letter and for a list of laboratories that can assist with the sampling. If you do not complete the required sampling before **April 30, 2019**, the continued non-compliance may result in additional enforcement action and may include the assessment of civil penalties as prescribed by OAR 333-061-0090.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels

Compliance Specialist

Oregon Health Authority, Drinking Water Services

cc: Zach Golik, Oregon Health Authority, Drinking Water Services
Justin Fimbres, Josephine County Environmental Health Services
Shawn Stevenson, Oregon Health Authority, Drinking Water Services