

June 25, 2019

Jill Snow
Loon Lake Lodge & RV Resort
9011 Loon Lake Road
Reedsport, OR 97467

RE: Reminder to monitor and report nitrate and surface water treatment measurements for the Loon Lake Lodge #1 public water system.

Dear Ms. Snow,

Nitrate monitoring and surface water treatment effectiveness have not been reported for your water system as required. As we discussed on June 24th, surface water treatment effectiveness must be calculated and reported every month according to OAR 333-061-0036(5)(b) and OAR 333-061-0040(1) respectively. Nitrate monitoring must be conducted and reported every year according to OAR 333-061-0036(2)(c) and OAR 333-061-0040(1).

These requirements should be completed as soon as possible, with surface water treatment effectiveness reported to the Oregon Health Authority (OHA) within 10 days of the end of every month for the remainder of the 2019 operating season. Nitrate monitoring must be reported to OHA within 30 days of the date of this letter.

Please contact me at 971-673-0407 if you have any questions about this letter, or contact Rebecca Templin at 541-726-2587, extension 29 if you have any questions about surface water treatment.

Thank you for your cooperation.

Respectfully,



Brad K. Daniels
Compliance Specialist
Oregon Health Authority, Drinking Water Services