PUBLIC HEALTH DIVISION Center for Health Protection, Drinking Water Services

John A. Kitzhaber, MD, Governor

Health Authority

800 NE Oregon St. Portland, Oregon 97232-2162 Voice (971) 673-0405 FAX (971) 673-0694 TTY (971) 673-0372

July 23, 2014

Mike Brown Meadow Wood RV Park 922 Old Town Loop Rd Oakland, OR 97462

RE: Failure to report sample results and possible civil penalties for Meadow Wood RV Park Public Water System, PWS OR4192123

Mr. Brown,

Our records indicate that you own and operate the Meadow Wood RV Park water system at 869 Autumn Lane in Glendale, Oregon. Therefore, you are a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule <u>OAR</u> 333-061-0020(211), and have specific responsibilities as defined in <u>OAR</u> 333-061-0025.

Meadow Wood RV Park is a transient non-community public water system serving approximately 28 people, and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005.

Upon review, the Meadow Wood RV Park water system has been found to be out of compliance with the following Oregon administrative rules, and you are therefore not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

DESCRIPTION OF RULE VIOLATIONS

Violation No. 1: OAR 333-061-0036(2) requires water suppliers to conduct annual nitrate sampling of the water supply. No nitrate tests have been reported since July of 2012. The Douglas County Health Department specifically requested the submission of nitrate sampling by June 15, 2014 in their letter dated May 27, 2014. However, this sampling has not been submitted as requested as of the date of this notice. This constitutes a violation of OAR 333-061-0036(2).

Meadow Wood RV Park Page 2

Violation No. 2: <u>OAR 333-061-0036(6)</u> requires water suppliers to conduct quarterly coliform sampling of the water supply. No coliform tests have been reported since July of 2012. The Douglas County Health Department specifically requested the submission of coliform sampling by June 15, 2014 in their letter dated May 27, 2014. However, this sampling has not been submitted as requested as of the date of this notice. This constitutes a violation of OAR 333-061-0036(6).

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, you are required to complete the following actions relating to the Meadow Wood RV Park water system:

- Compliance Action No. 1: You must ensure samples are collected in accordance with OAR 333-061-0036(2) and report samples results no later than **August 15, 2014** to return to compliance with OAR 333-061-0036(2).
- Compliance Action No. 2: You must ensure samples are collected in accordance with OAR 333-061-0036(6) and report samples results no later than **August 15, 2014** to return to compliance with OAR 333-061-0036(6).

The failure to submit the sample results as specified above puts you at risk of being assessed civil penalties in the amount of \$50 for every distinct rule violation and for every day the Meadow Wood RV Park water system is in violation of rule OAR 333-061-0090.

In the event that DWS assesses a civil penalty against you, you will be notified in writing and provided an opportunity for a hearing pursuant to the Oregon Administrative Procedures Act (ORS chapter 183).

To avoid being assessed civil penalties, you must immediately complete the actions specified in this letter.

Respectfully,

El L Deel

Meadow Wood RV Park Page 2

Brad Daniels Enforcement Coordinator OHA - Drinking Water Services

cc: Douglas County Environmental Health
OHA Drinking Water Services Technical Representative