

February 16, 2017

Fang Chung Lee
Smith River RV Park and Marina
11777 Pipeline Avenue
Chino, CA 91710

RE: Notice of failure to correct significant deficiencies at the Smith River RV Park and Marina public water system

Records indicate you own the Smith River Marina (Smith River) public water system located at 8451 Lower Smith River Road in Reedsport, Oregon. The Smith River water system is a transient non-community public water system identified by ID# OR4192133 that serves approximately 30 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rules 333-061-0005 to 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) has reviewed the operation of the Smith River water system. This review has found that you are not in compliance with OAR 333-061-0076(6)(b) and therefore not meeting your responsibilities as a water supplier.

OAR 333-061-0076(6)(b) requires water suppliers to correct significant deficiencies within 120 days of notification or to be in compliance with an approved corrective action schedule. You have not reported that significant deficiencies were corrected by the December 31, 2014 due date at the Smith River water system. One deficiency, the lack of a watertight roof and hatch for the water storage facility, is considered a direct pathway for contamination to enter a water system and is a priority for correction. The failure to correct this deficiency by the due date following the August 28, 2014 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6).

You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Smith River water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0407 if you have any questions about the compliance action specified in this letter.

Respectfully,

A handwritten signature in blue ink, appearing to read "BK Daniels", is shown on a light-colored rectangular background.

Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: John Garzand, Smith River Marina
Caroline Gross-Regan, Douglas County Environmental Health