

January 10, 2019

Tom Bartel
Paradise Trail Christian Camp
12647 SW 62nd Ave
Portland, OR 97219

RE: Notice of failure to correct significant deficiencies at the Paradise Trail Lodge public water system

Records indicate that Paradise Trail Christian Camp owns the Paradise Trail Lodge public water system located at 39 Road, Rhododendron OR 97049. The Paradise Trail Lodge water system is a transient non-community public water system identified by ID# OR4193558 that serves approximately 25 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. Paradise Trail Christian Camp is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Paradise Trail Lodge water system. This review has found that Paradise Trail Christian Camp is not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier. OAR 333-061-0076(6) requires water suppliers to either correct significant deficiencies or comply with an approved corrective action schedule following a sanitary survey.

You have not reported that the significant deficiencies from the Nov. 20, 2017 survey at the Paradise Trail Lodge water system were corrected by the May 30, 2018 deadline. One deficiency, lack of screen on the existing well vent, is considered a direct pathway for contamination to enter a water system and is a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this deficiency is corrected within 30 days of the date of this

notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50.00 for every distinct rule violation and for every day the Paradise Trail Lodge water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,

A handwritten signature in blue ink that reads "Abbie Spielman". The signature is written in a cursive style and is set against a light gray rectangular background.

Abbie Spielman
Oregon Health Authority, Drinking Water Services

cc: Joel Ferguson, Clackamas County Environmental Health
James Nustrala, Drinking Water Services
Pete Farrelly, Drinking Water Services