

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

November 28, 2017

Joel McElhannon
Rome Station
3605 US Hwy 95 S
Jordan Valley, OR 97910

RE: Notice of failure to correct significant deficiencies at the Rome Station public water system, ID# OR4193645


This letter is to inform you the Oregon Health Authority was not notified that significant deficiencies were corrected by the May 25, 2017 due date at the Rome Station public water system. One of the deficiencies, lack of watertight sanitary seal and casing at the well, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date following the May 19, 2016 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0421. Your immediate attention to this matter is appreciated.

Respectfully,



Janet Brock
Oregon Health Authority, Drinking Water Services

cc: Bill Goss, Oregon Health Authority, Drinking Water Services
Craig Geddes, Eric Evans, Malheur County Health Department