

October 27, 2016

Anthony and Mindy Simon  
King Silver RV Park & Marina  
3703 Alsea Hwy  
Waldport, OR 97394

RE: Microscopic Particulate Analysis at the King Silver RV Park public water system.

Dear Anthony and Mindy Simon,

The Oregon Health Authority, Drinking Water Services (DWS) determined Well A, known as the East Well serving your water system must be evaluated for influence by surface water because of its proximity to the Alsea River and surrounding wetland. This evaluation is required by Oregon Administrative Rule (OAR) 333-061-0032(8). You must therefore collect at least two samples for microscopic particulate analysis as soon as possible, depending on weather conditions. The samples must be collected at least 30 days apart and only after periods of heavy rainfall or snowmelt.

Please contact Shawn Stevenson at 541-726-2587, extension 32 if you have any questions about this letter and for a list of laboratories that can assist with the sampling and analysis.

If you do not complete the required sampling before the summer of 2017 you may be referred for further enforcement action, which could include the assessment of civil penalties according to OAR 333-061-0090.

Respectfully,



Brad K Daniels, Compliance Specialist  
Oregon Health Authority, Drinking Water Services

cc: Amy Chapman, Lincoln County Environmental Health  
Tia Skerbeck, Oregon Health Authority, Drinking Water Services  
Shawn Stevenson, Oregon Health Authority, Drinking Water Services