

April 23, 2015

Jagmohan Singh
Center Market #25
1283 SW Fairview
Dallas, OR 97338

RE: Notice of Non-Compliance regarding the Center Market #25 Public Water System

Mr. Singh:

Our records indicate that you own and operate the Center Market #25 water system located at 9005 River Rd. NE, Keizer, Oregon, and identified by ID number OR4194623. Therefore, you are a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and have specific responsibilities as defined in OAR 333-061-0025.

Center Market #25 is a transient non-community public water system, which serves approximately 250 people, and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) mailed a letter to you on November 6, 2014 identifying the failure to report required sampling results for the Center Market #25 water system. The letter identified sampling to be conducted and a deadline for reported results to DWS. Sample results were not reported as specified in the letter, and you are, therefore, not in compliance with the following Oregon administrative rules and not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(2), in part, requires water suppliers to conduct sampling for nitrate at public water systems, but you did not report nitrate sampling results for the Center Market #25 water system for the 2013 and 2014 yearly monitoring periods, which constitutes two violations of OAR 333-061-0036(2) if samples were, in fact, not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, you are required to complete the following actions relating to the Center Market #25 water system:

- Compliance Action No. 1: You are required to monitor for nitrate according to OAR 333-061-0036(2)(d) and report the sample results to DWS no later than **June 10, 2015**.

If you do not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact Brian Hawkins at the Oregon Department of Agriculture at 503-508-6028 to discuss the compliance actions specified in this letter.

Thank you for your cooperation.

Respectfully,



Janet Brock
Compliance Specialist
Oregon Health Authority, Drinking Water Services

cc: Brian Hawkins, Oregon Department of Agriculture
Gregg Baird, Oregon Health Authority, Drinking Water Services
Rosy Kaur, Manager