



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

February 20, 2024

Richard Craig
Juniper Grove RV Park
11201 N El Mirage F120
El Mirage, AZ 85335

RE: Notice of failure to correct significant deficiencies at the Juniper Grove RV
Park public water system

Records indicate you, Richard Craig, own the public water system serving the Juniper Grove RV Park (hereinafter “Water System”), located at 11712 E Davis Loop Road in Prineville, Oregon. Richard Craig (hereinafter “Water Supplier”), you are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020 and have specific responsibilities as defined in OAR 333-061-0025.

The Water System is identified by public water system ID# OR4194695 and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.

OAR 333-061-0076(6)(b) requires, in part, water suppliers responsible for water systems using only groundwater sources to have corrected any significant deficiencies identified during a sanitary survey, or to comply with an approved corrective action plan, within 120 days of written notice of the deficiency. A sanitary survey was conducted on April 20, 2023 at the Water System and a letter was mailed to Water Supplier on May 11, 2023 identifying a significant deficiency discovered during the survey. The letter required this deficiency, the lack of a watertight roof or access hatch for a finished water storage facility, be corrected by September 14, 2023. That date passed without the correction of the deficiency and without DWS approval of a corrective action plan. This constitutes a violation of OAR 333-061-0076(6)(b).

Juniper Grove RV Park


Page 2

Additionally, this deficiency is considered a direct pathway for contamination to enter a water system and is a priority for correction.

Please submit written verification to me at bradley.k.daniels@oha.oregon.gov that this deficiency is corrected within 30 days of the date of this notice.

If Water Supplier does not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at bradley.k.daniels@oha.oregon.gov or (503) 735-5438 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Bruce Fremont, Juniper Grove RV Park
Bill Goss, Oregon Health Authority, Drinking Water Services
Max Hamblin, Crook County Environmental Health
Amy Word, Oregon Health Authority, Drinking Water Services