

3/9/2026

LAXMI CHIMARIYA
COTTONWOODS MARKET
35867 KNOX BUTTE RD E
ALBANY, OR 97321

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4194733

Dear LAXMI CHIMARIYA,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 9/3/2026. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Ryley Gilbert at (503) 551-2593.

Respectfully,

Drinking Water Services

cc: Nick Alviani, DWS

Ryley Gilbert, DEPT OF AGRICULTURE