

November 23, 2020

Daniel Barker
Prineville Missionary Baptist Church
PO Box 691
Prineville, OR 97754

RE: Notice of failure to correct significant deficiencies at the Prineville Missionary Baptist Church public water system

Records indicate the Prineville Missionary Baptist Church owns the public water system (hereinafter "Water System") located at 1870 NW Riverland Loop in Prineville, Oregon. The Prineville Missionary Baptist Church (hereinafter "Water Supplier") is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Water System is a transient non-community public water system identified by ID# OR4194816 that serves approximately 40 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.

The Oregon Health Authority, Drinking Water Services (DWS) has reviewed the operation of the Water System. This review has found that Water Supplier is not in compliance with OAR 333-061-0076(5) and therefore not meeting its responsibilities as a water supplier.

OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies or to be in compliance with an approved corrective action schedule. Water Supplier has not reported that significant deficiencies were corrected by the March 17, 2020 due date at the Water System. One deficiency, the lack of a watertight casing and sanitary seal for the Water System's groundwater well, is considered a direct pathway for contamination to enter a water system and is a priority for correction. The failure to correct this deficiency by the due date following the November 12, 2019 sanitary survey is a violation of OAR 333-061-0076(5) and (7).

Please submit written verification to me that this deficiency is corrected within 30 days of the date of this letter.

If Water Supplier does not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0407 or at bradley.k.daniels@dhsosha.state.or.us if you have any questions about the compliance action specified in this letter.

Respectfully,

A handwritten signature in blue ink, appearing to read "BK Daniels", is placed over a light gray rectangular background.

Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Max Hamblin, Crook County Environmental Public Health