

January 29, 2019

Bruce Bronson
East Lake RV Park/East Lake Resort
PO Box 95
La Pine OR 97703

RE: Notice of failure to correct significant deficiencies at the East Lake RV Park public water system

Records indicate that you own the East Lake RV Park (East Lake) public water system serving the RV park, vacation cabins, camp ground, and restaurant collectively known as the East Lake Resort located at 22430 Paulina Lake Road, La Pine OR 97739. The East Lake water system is a transient noncommunity public water system identified by ID# OR4194862 that serves approximately 50 people and is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 to OAR 333-061-0272. You are therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and have specific responsibilities as defined in OAR 333-061-0025.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the East Lake water system. This review has found that you are not in compliance with OAR 333-061-0076(6) and therefore not meeting your responsibilities as a water supplier. OAR 333-061-0076(6) requires water suppliers to correct significant deficiencies or comply with an approved corrective action schedule.

You have not reported that the significant deficiencies from the July 17, 2018 survey at 100 East Lake were corrected by the Nov. 13, 2018 deadline. One deficiency, sanitary seal and casing not watertight, is considered a direct pathway for contamination to enter a water system and a priority for correction. The failure to correct this deficiency by the due date following the sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6). You must submit written verification to me that this deficiency is corrected within 30 days of the date of this notice.

If you do not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$50.00 for every distinct rule violation and for every day the East Lake water system is in violation of a rule as prescribed by OAR 333-061-0090. Please contact me at (971) 673-0461 if you have any questions about the compliance action specified in this letter.

Respectfully,



Abbie Spielman
Oregon Health Authority, Drinking Water Services

cc: Jeff Freund, Deschutes County Environmental Health
Michelle Byrd, Drinking Water Services