

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

BEFORE THE STATE OF OREGON
OREGON HEALTH AUTHORITY
PUBLIC HEALTH DIVISION
CENTER FOR HEALTH PROTECTION

In the Matter of

Dardanelle's Community Store, Public
Water System OR4194921

Respondent

NOTICE OF VIOLATION AND
ADMINISTRATIVE ORDER

To: Dawni Stockton
Dardanelle's Community Store
9625 Old Stage Road
Central Point, OR 97502

You have at all times mentioned herein owned and operated, and continue to own and operate the Dardanelle's Community Store water system (hereinafter "Water System") located at 9625 Old Stage Road in Central Point, Oregon. The Water System is a transient non-community public water system serving approximately 80 people, and is subject to regulation under Oregon Revised Statutes 448.115 to 448.290 and Oregon Administrative Rules 333-061-0005 to 333-061-0272.

You are therefore a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020, and as a water supplier, have specific responsibilities that are identified in OAR 333-061-0025.

Pursuant to its authority established in ORS 431A.010 and ORS 448.255, the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has investigated the operation of the Water System and found that you

did not report monitoring for nitrate as required by rule. You are therefore unable to assure your water users that the water is sufficiently free from contaminants such that individuals will not be exposed to disease or harmful physiological effects (ORS 448.115(8)). This represents a potential public health hazard.

This Notice of Violation and Administrative Order (Order) is being issued to you for the specific violations of the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules found during DWS' investigation as described below.

DESCRIPTION OF RULE VIOLATIONS

1. OAR 333-061-0025(1) requires water suppliers to routinely collect and submit water samples for laboratory analyses at the frequencies prescribed by OAR 333-061-0036. OAR 333-061-0036(2)(c) requires monitoring for nitrate at public water systems, but you did not report sample results to DWS according to the rule, which constitutes a violation of OAR 333-061-0025(1) if samples were in fact not collected.
2. OAR 333-061-0036(2)(c) requires water suppliers to monitor for nitrate at least once every year at public water systems. Additionally, OAR 333-061-0040(1)(b)(A) requires water suppliers to report monitoring required by OAR 333-061-0036 to DWS within 10 days of the end of the required monitoring period. You have not reported nitrate monitoring for the Water System since reporting a sample collected on May 4, 2015. This constitutes a violation of OAR 333-061-0036(2)(c), or a violation of OAR 333-061-0040(1)(b)(A) if monitoring was conducted but not reported.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

You are required to conduct the remedial actions described below which, if taken within the time specified in this Order, will effect compliance with the rule(s) violated (ORS 448.255(3)).

- Compliance Action No. 1: You must monitor for nitrate at the Water System according to OAR 333-061-0036(2)(c) and report the monitoring results to DWS no later than August 31, 2018.

GENERAL PROVISIONS AND CIVIL PENALTIES

This Order does not constitute a waiver, suspension or modification of the requirements of the Oregon Drinking Water Quality Act (ORS 448.115 to 448.290) and Oregon Administrative Rules OAR 333-061-0005 to 333-061-0272, which remain in full force and effect.

This Order does not relieve you of any responsibilities or liabilities established pursuant to any applicable federal, state, or local law or regulation.

Issuance of this Order is not an election by DWS to forgo any civil actions authorized under the Oregon Drinking Water Quality Act.

Failure to comply with any of the requirements in this Order by the specified due date may result in additional enforcement action, which could include assessment of civil penalties in the amount of \$50 per day per violation (OAR 333-061-0090). Civil penalties may be assessed beginning the day following the date of service of this Order and accruing through the date when DWS issues a Notice of Intent to Impose Civil Penalty. For example, if DWS issues a Notice of Intent to Impose Civil Penalty on September 1, 2018 for failure to monitor for nitrate according to this Order, the proposed civil penalty could be as much as \$3,600.

Pursuant to ORS 448.990(2), violations of a rule of the Oregon Health Authority may be a crime in Oregon and punishable as a Class A misdemeanor.

NOTICE OF RIGHT TO REQUEST A HEARING

You are entitled to a hearing as provided by the Administrative Procedure Act (Oregon Revised Statutes, Chapter 183). If you want a hearing you must file a written request for hearing with DWS within 10 days from the date this Order was mailed. **The request for hearing must be sent to: David Emme, Manager; Oregon Health Authority, Drinking Water Services; PO Box 14450; Portland, OR 97293.**

If you request a hearing, DWS will notify you of the time and place at which the hearing will be held. You may enlist representation by legal counsel. Per ORS 413.041, a party that is not a natural person may be represented by an attorney or by any officer or authorized agent or employee of the party. Parties are ordinarily represented by counsel. The Authority will be represented by an Assistant Attorney General. Prior to the hearing date, DWS will provide you with information on the procedures, right of representation and other rights of parties relating to the conduct of the hearing. An administrative law

judge from the Office of Administrative Hearings will be assigned to preside over the hearing, as required by ORS 183.635.

If you do not make a timely request for a hearing, the Notice of Violation and Administrative Order will become final and effective 11 days after the date this Order was mailed. If the Order becomes final in this manner, you will have the right to appeal the order to the Oregon Court of Appeals pursuant to ORS 183.482. To appeal you must file a petition for judicial review with the Court of Appeals within 71 days from the day this order was mailed. If you do not file a petition for judicial review within the 71-day time period, you will lose your right to appeal.

If you do not request a hearing and DWS subsequently issues a Notice Imposing a Civil Penalty, you will have waived any right to contest the violations.


If you withdraw a request for hearing, or notify DWS or the administrative law judge that you will not appear or fail to appear at a scheduled hearing, DWS may issue a final order by default. If the Order becomes final in this manner, you will have the right to appeal the Order to the Oregon Court of Appeals pursuant to ORS 183.482. To appeal you must file a petition for judicial review with the Court of Appeals within 60 days from the day this Order was mailed. If you do not file a petition for judicial review within the 60-day time period, you will lose your right to appeal.

Notice to Active Duty Service members. Active duty service members have a right to stay proceedings under the federal Service members Civil Relief Act and may contact the Oregon State Bar at 1 (800) 452-8260 or the Oregon Military Department at 1 (800) 452-7500 for more information. The internet address for the United States Armed Forces Legal Assistance Locator website is <http://legalassistance.law.af.mil/content/locator.php>.

DWS has designated its complete file on the Water System as the record in this case for purposes of proving a prima facie case upon default.

If you need to receive the information in this Order in an alternate format, or if you have any questions about the requirements in this Order, please contact Brad K. Daniels at 971-673-0405.


Dated this 13th day of June, 2018.



David Emme, Manager
Drinking Water Services
Oregon Health Authority

cc: Russ Kazmierczak, Oregon Health Authority, Drinking Water Services
Shane Kinney, Malheur County Environmental Health

DATE of Service: June 18, 2018



Brad K. Daniels

By certified mail and first class mail