



PUBLIC HEALTH DIVISION
Drinking Water Program

Kate Brown, Governor

Oregon
Health
Authority

2860 State Street
Medford, OR 97504
(541) 618-7872
FAX: 541-772-2201
scott.g.curry@state.or.us

March 16, 2015

Ed Murdock
99040 S. Bank Chetco River Rd.
Brookings, OR 97465

**RE: Monthly assessment monitoring required
Salmon Run Golf Course (PWS #4195127)**

Dear Mr. Murdock:

We have determined that, due to last December's detection of E. coli in the water system serving Salmon Run Golf Course, additional water quality monitoring is required. This requirement is also driven by the sensitivity of the aquifer and the proximity of surface water to the well.

Beginning in April of this year, please submit monthly raw water assessment samples from the well for a total of 12 months. These samples must be taken prior to any treatment (chlorination, UV, etc.). These samples are separate from your routine quarterly samples that are taken from the distribution system. Please be sure that the lab slips are marked accordingly.

Thank you very much for your cooperation, and please contact me if you have any questions.

Sincerely,

Scott G. Curry, P.E.
Regional Engineer
Drinking Water Program

cc: Brody Hodges, Curry Community Health