



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Kate Brown, Governor



800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

2/23/2022

JIM EDWARDS

LORANE FAMILY STORE

80301 TERRITORIAL RD

LORANE, OR 97451

RE:Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4195141

Dear JIM EDWARDS,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 8/25/2022. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Jeff Green at (541) 913-8837.

Respectfully,

Drinking Water Services

cc: Jay MacPherson, DWS

Jeff Green, DEPT OF AGRICULTURE