

June 6, 2016

Michael Curry  
Michael Curry Design  
50759 Dike Rd.  
Scappoose, OR 97056

RE: Notice of Non-Compliance Regarding the Michael Curry Design Public Water System

Mr. Curry,

Our records indicate that Michael Curry Design, Inc. owns and operates the Michael Curry Design water system located at 50759 Dike Road, Scappoose, Oregon. Therefore, Michael Curry Design, Inc. is a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(211), and has specific responsibilities as defined in OAR 333-061-0025.

The Michael Curry Design water system is a non-transient non-community public water system identified by public water system ID OR41-95224, serves approximately 25 people, and is subject to regulation according to ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Michael Curry Design water system. This review has found that Michael Curry Design, Inc. is not in compliance with the following Oregon Administrative Rules, and is therefore not meeting its responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

#### DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(2)(c) requires sampling for lead and copper for public water systems. DWS received lead and copper results of samples collected May 22, 2012. However, OAR 333-061-0036(2)(d)(IV) requires systems which monitor annually or once every three years to conduct sampling during the warmest months of June, July, August or September. DWS has not received samples collected

during those months since July 18, 2011, which constitutes a violation of the rule if samples were, in fact, not collected.

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, Michael Curry Design, Inc. is required to complete the following actions relating to the Michael Curry Design water system:

- Compliance Action No. 1: Collect lead and copper samples in accordance with OAR 333-061-0036(2)(c) and report sample results to DWS no later than October 10, 2016.
  - Lead and copper samples must be collected after June 1, 2016 and before September 30, 2016. Samples collected before June 1, 2016 and after September 30, 2016 will not qualify for compliance or satisfy this compliance action.

If Michael Curry Design, Inc. does not comply with the deadlines specified in this letter, the continued non-compliance may result in additional enforcement action including the assessment of civil penalties as prescribed by OAR 333-061-0090. Please contact Joel Ferguson at Columbia County Environmental Health at (503) 366-3828 to discuss the compliance actions specified in this letter.

Respectfully,



Janet Brock  
Compliance Specialist  
Oregon Health Authority, Drinking Water Services

cc: James Nusrala, Oregon Health Authority, Drinking Water Services  
Joel Ferguson, Columbia County Environmental Health