



PUBLIC HEALTH DIVISION  
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon  
**Health**  
Authority

800 NE Oregon St.  
Portland, Oregon 97232-2162  
Voice (971) 673-0405  
FAX (971) 673-0694  
TTY (971) 673-0372

February 22, 2023

Joshua Tanner  
Bandon Christian Fellowship  
1190 Face Rock Drive  
Bandon, OR 97411

RE: Notice of failure to correct significant deficiencies at the Bandon Christian Fellowship public water system

Records indicate Bandon Christian Fellowship owns and operates the public water system (hereinafter "Water System"), identified by public water system ID# OR4195311 and located at 1190 Face Rock Drive in Bandon, Oregon. Bandon Christian Fellowship (hereinafter "Water Supplier") is therefore a water supplier as defined in ORS 448.115(12) and OAR 333-061-0020(150) and has specific responsibilities as defined in OAR 333-061-0025.

The Water System is subject to regulation according to the Oregon Drinking Water Quality Act (Oregon Revised Statutes 448.115 to 448.290) and Oregon Administrative Rule (OAR) 333-061-0005 through OAR 333-061-0272.

OAR 333-061-0076(5) requires water suppliers to correct significant deficiencies identified during sanitary surveys or to comply with an approved corrective action schedule. The Oregon Health Authority, Drinking Water Services (DWS) reviewed the operation of the Water System and found that two significant deficiencies remain uncorrected following two consecutive sanitary surveys:

1. Failure to maintain a current operations and maintenance manual; and
2. Failure to maintain a coliform sampling plan.

Water Supplier has not reported that these deficiencies were corrected by the specified due dates, following the surveys conducted on December 9, 2016 and April 8, 2021 respectively. Water Supplier is therefore not in compliance with OAR 333-061-0076(5) and not meeting its responsibilities as a water supplier.

Please submit written verification to [bradley.k.daniels@oha.oregon.gov](mailto:bradley.k.daniels@oha.oregon.gov) within 30 days of the date of this notice, demonstrating that these deficiencies were corrected.

If Water Supplier does not comply with the deadline specified in this letter, the continued non-compliance may result in additional enforcement action, which could include the assessment of civil penalties in the amount of \$100 for every distinct rule violation and for every day the Water System is in violation of a rule as prescribed by OAR 333-061-0090. Contact me at [bradley.k.daniels@oha.oregon.gov](mailto:bradley.k.daniels@oha.oregon.gov) or (503) 735-5438 if you have any questions about the compliance action specified in this letter.

Respectfully,



Brad K. Daniels

Oregon Health Authority, Drinking Water Services

cc: Kent Downs, Oregon Health Authority, Drinking Water Services  
Rick Hallmark, Coos County Environmental Public Health