

October 13, 2016

Lisa Anheluk
U. S. Forest Service
63095 Deschutes Market Rd.
Bend, OR 97701

RE: Notice of failure to correct significant deficiencies at the Cascade Lakes Welcome Station public water system, ID# OR4195543

This letter is to inform you the Oregon Health Authority has not been notified that significant deficiencies were corrected by the March 18, 2016 due date at the Cascade Lakes Welcome Station water system. One of the deficiencies, that the sanitary seal and casing is not watertight for the water system's well, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date following the November 12, 2015 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact me at 971-673-0407. Your immediate attention to this matter is appreciated.

Respectfully,



Brad K. Daniels
Oregon Health Authority, Drinking Water Services

cc: Joel Ferguson, Clackamas County Environmental Health