



**PUBLIC HEALTH DIVISION
Drinking Water Services**

Kate Brown, Governor

**Oregon
Health
Authority**

800 NE Oregon Street, #640

Portland, OR 97232-2162

Phone 971-673-0405

FAX 971-673-0694

TTY-Nonvoice 971-673-0375

11/7/2022

ANGELA JAQUETTE
SILVAN RIDGE WINERY
27012 BRIGGS HILL ROAD
EUGENE, OR 97405

RE: Installation of treatment to maintain a disinfectant residual due to persistent coliform bacteria at OR4195628

Dear ANGELA JAQUETTE,

Due to recent coliform sample results, the Oregon Health Authority, Drinking Water Services (DWS) is requiring another coliform investigation. The number of coliform investigations at your water system without removing the source of the coliform bacteria requires the installation of treatment to maintain a disinfectant residual throughout the distribution system according to Oregon Administrative Rule 333-061-0032(6)(g).

Treatment must be installed no later than 5/3/2023. Plan review is required prior to installation. Please review the requirements at www.healthoregon.org/pwsplanreview.

If you have any questions please contact Jeff Green at (541) 913-8837.

Respectfully,

Drinking Water Services

cc: Amy Bleekman, DWS

Jeff Green, DEPT OF AGRICULTURE