



800 NE Oregon Street, Suite #640
Portland, OR 97232-2162
(971) 673-0405
(971) 673-0694 – FAX
<http://healthoregon.org/dwp>

June 24, 2024

Mario Acosta
Heather Oak Wood Products, Inc.
PO Box 40457
Eugene, OR 97404

RE: Violation of the maximum contaminant level for *E. coli* bacteria at the Heather Oak Wood Products, Inc. public water system, ID# 95632

Dear Mario Acosta,

Recent samples reported for your water system indicate coliform bacteria in the drinking water caused a violation of the maximum contaminant level (MCL) for *E. coli* bacteria. The presence of these bacteria indicates that the water may be contaminated with human or animal wastes. Human pathogens in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a greater health risk for infants, young children, the elderly, and people with severely compromised immune systems. OAR 333-061-0097

Please consult with Nicholas Alviani at 541-682-4480 as necessary so that you can disinfect the water system and abate the contamination as quickly as possible.

- 1) You must cooperate with Nicholas Alviani to correct the sanitary defects identified during the investigation conducted at your water system on June 5, 2024, and afterward collect water samples to demonstrate bacteria are no longer present in the drinking water of the water system.

The actions described in this letter are required by Oregon Administrative Rules 333-061-0025, 333-061-0030 and 333-061-0042. Please contact me at bradley.k.daniels@oha.oregon.gov or (503) 735-5438 if you have any questions or to discuss the actions required in this letter.

Thank you for your immediate attention to this matter.

Respectfully,

A handwritten signature in blue ink, appearing to read "BK Daniels".

Brad K. Daniels

Compliance Specialist

Oregon Health Authority, Drinking Water Services

cc: Nicholas Alviani, Lane County Environmental Health
Amy Bleekman, Oregon Health Authority, Drinking Water Services