



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	<del>CaCO<sub>3</sub></del>	CaCO <sub>3</sub>	SiH	Y/N
4/1	7.9	1.0			Y
4/2	7.9				Y
4/3	7.9				Y
4/4	8.1	1.1			Y
4/7	8.1				Y
4/8	8.0				Y
4/11	7.8	1.1			Y
4/12	7.9				Y
4/13	7.8				Y
4/16	7.9	1.0			Y
4/17	7.9				Y
4/18	7.9				Y
4/21	8.0				Y
4/22	8.1	1.0			Y
4/23	8.0				Y
4/26	7.9				Y
4/27	7.9				Y
4/28	7.9				Y
4/30	7.9				Y

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 4-21

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	12	
Alk		(Alkalinity)
PO4		(Orthophosphate)
Si		(Silicate)

Print Name: Don Van Fatta

Signature: *Don Van Fatta*

Date: 5-5-21