



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Chlorine

Day	pH	Chlorine	CaCO ₃	Sili	Y/N
6/1	8.0	1.2			Y
6/2	8.0				Y
6/3	8.0				Y
6/6	7.9	1.2			Y
6/7	7.9				Y
6/8	8.0				Y
6/11	7.9	1.1			Y
6/12	7.9				Y
6/13	7.9				Y
6/14	8.0	1.1			Y
6/17	8.1				Y
6/18	8.1				Y
6/19	8.0	1.1			Y
6/20	8.1				Y
6/23	8.0				Y
6/24	8.0	1.0			Y
6/25	8.0				Y
6/26	7.9				Y
6/29	7.9	1.1			Y
6/30	7.9				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 4

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 6-21

Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Don Van Eaton
 Signature: Don Van Eaton
 Date: 7-2-21

Excursions Total N's (0)