



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

chlorine

Day	pH	Chlorine	CaCO <sub>3</sub>	Sili	Y/N
7/1	7.8	1.1			Y
7/2	7.9				Y
7/3	7.9				Y
7/6	7.7	1.1			Y
7/7	7.9				Y
7/8	8.0				Y
7/9	8.0				Y
7/11	8.0	1.0			Y
7/12	7.9				Y
7/13	7.9				Y
7/14	7.9				Y
7/17	8.1	1.0			Y
7/18	8.1				Y
7/19	8.0				Y
7/21	7.9				Y
7/22	7.9	1.1			Y
7/23	7.9				Y
7/24	8.0				Y
7/27	7.7				Y
7/28	7.7	1.0			Y
7/29	7.8				Y
7/30	7.9				Y

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 7-21  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

#### Minimum Water Quality Parameters as set by State:

pH	7.2	
Alk		(Alkalinity)
PO <sub>4</sub>		(Orthophosphate)
Sili		(Silicate)

Print Name: Don Van Eater  
Signature: Don Van Eater  
Date: 8-4-21

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling  
(502) 738-1111