



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	chlorine	CaCO ₃	Sili	Y/N
12/1	7.9	.9			Y
12/2	7.8				Y
12/3	7.8				Y
12/6	8.0	1.1			Y
12/7	7.9				Y
12/8	7.9				Y
12/11	7.8				Y
12/12	7.9	1.0			Y
12/13	7.9				Y
12/16	8.1				Y
12/17	8.0				Y
12/18	8.0	1.1			Y
12/21	7.9				Y
12/22	7.9				Y
12/23	7.9				Y
12/26	7.8	.9			Y
12/27	7.9				Y
12/28	7.9				Y
12/31	7.9	1.0			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 4

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 12-21

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Logan Levine

Signature: [Handwritten Signature]

Date: 1-5-22

(No = N = Excursion) Total N's