

chloride

Day	pH	<del>CaCO<sub>3</sub></del>	CaCO <sub>3</sub>	Sili	Y/N
1/1	7.9	.8			Y
1/2	7.9				Y
1/3	7.9				Y
1/6	7.7	.8			Y
1/7	7.8				Y
1/8	7.7				Y
1/11	7.7				Y
1/12	7.7	1.0			Y
1/13	7.8				Y
1/16	7.9				Y
1/17	7.9				Y
1/18	7.8				Y
1/21	7.9	1.0			Y
1/22	7.9				Y
1/23	7.9				Y
1/26	7.8	1.1			Y
1/27	7.8				Y
1/28	7.9				Y
1/31	7.9	1.1			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 0 0 0 0

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 1-22

Month/Year

Number of excursions\* during this month  
(Count the number of days when any WQI than the minimum required)

Total excursions during the previous 5 m  
(Over 9 excursions in 6 months is a violation. Point and Distribution excursions are cum)

\*For DHS use only

Minimum Water Quality Parameters as set by State

pH	7.2	
Alk		(Alkalinity)
PO4		(Orthophosph)
Sili		(Silicate)

Print Name: Don Logan Lewis  
 Signature: Don Logan Lewis  
 Date: 2-4-22

(No = N = Excursion) Total N's 0