

Chlorine

| Day | pH | Chlorine | CaCO ₃ | Sili | Y/N |
|------|-----|----------|-------------------|------|-----|
| 7/1 | 7.7 | 1.0 | | | Y |
| 7/2 | 7.7 | | | | Y |
| 7/3 | 7.8 | | | | Y |
| 7/6 | 7.9 | .9 | | | Y |
| 7/7 | 7.8 | | | | Y |
| 7/8 | 7.8 | | | | Y |
| 7/11 | 7.7 | .9 | | | Y |
| 7/12 | 7.7 | | | | Y |
| 7/13 | 7.9 | | | | Y |
| 7/16 | 7.8 | 1.0 | | | Y |
| 7/17 | 7.9 | | | | Y |
| 7/18 | 7.9 | | | | Y |
| 7/21 | 7.9 | 1.0 | | | Y |
| 7/22 | 7.8 | | | | Y |
| 7/23 | 7.8 | | | | Y |
| 7/26 | 7.8 | 1.1 | | | Y |
| 7/27 | 7.9 | | | | Y |
| 7/28 | 7.9 | | | | Y |
| 7/31 | 7.9 | 1.1 | | | Y |

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 7-27

Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

| | | |
|------|-----|------------------|
| pH | 7.2 | |
| Alk | | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Sili | | (Silicate) |

Print Name: ~~John~~ Logan Leuane

Signature: *Logan Leuane*

Date: 8-5-22

(No = N = Excursion) Total N's: 0