



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Chlorine c.c./l.	CaCO ₃	Sill	Y/N
12/1	7.9	1.0			Y
12/2	7.9				Y
12/3	7.9				Y
12/6	7.9	.9			Y
12/7	7.8				Y
12/8	7.9				Y
12/10	7.9	.9			Y
12/12	7.9				Y
12/13	7.8				Y
12/16	7.8	1.1			Y
12/17	7.8				Y
12/18	7.9				Y
12/21	7.9	1.1			Y
12/22	7.9				Y
12/23	7.9				Y
12/26	7.9	1.0			Y
12/27	7.8				Y
12/28	7.8				Y
12/31	7.9	1.0			Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 12-22
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 3 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO ₄	<input type="text"/>	(Orthophosphate)
Sill	<input type="text"/>	(Silicate)

Print Name: Logan LeJane

Signature: [Signature]

Date: 1-3-23

(No = N = Excursion) Total N's