



Charlotte

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	CaCO ₃	Sili	Y/N
2/2	7.8	1.1		Y
2/2	7.8			Y
2/3	7.9			Y
2/6	7.9	1.0		Y
2/7	7.9			Y
2/8	7.9			Y
2/11	7.9	1.0		Y
2/12	7.8			Y
2/13	7.8			Y
2/16	7.7	1.1		Y
2/17	7.9			Y
2/18	7.9			Y
2/21	7.9	1.1		Y
2/22	7.9			Y
2/23	7.9			Y
2/24	7.9	1.0		Y
2/27	7.9			Y
2/28	7.9	1.0		Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Albany Trailer Court

Entry Point: Water Room

Sample Period: 2-23

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 3 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO ₄	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Logan Levarie

Signature: [Signature]